

## **SECTION 3910 - COMPRESSION COUPLINGS**

### **PART 1 - GENERAL**

#### **1.1 SCOPE OF WORK:**

Provide all labor, materials, equipment and services required for furnishing and installing compression couplings specified herein.

### **PART 2 - PRODUCTS**

#### **2.1 COMPRESSION COUPLINGS:**

When joining different types of pipe together or new pipe to existing pipe, the CONTRACTOR shall use Fernco Compression Couplings, or equal, that are resistant to corrosion by soil and sewage and that will provide a permanent watertight joint. The compression coupling shall meet the physical test and joint-leak requirements specified in ASTM C-594. The bands for attaching pipes shall be stainless steel conforming to ASTM C-594. Each coupling shall bear the manufacturer's name and an indication of its size. Compression couplings shall only be used where approved by the OWNER.

### **PART 3 - BASIS OF PAYMENT**

Furnishing and installing compression couplings is not a pay item. The cost shall be included with the unit cost per linear foot of gravity sewer.

END OF SECTION