



SUPPORT BRACKET & STAINLESS STEEL HOSE CLAMPS TO BE USED WHEN THE SERVICE PIPE ON THE BUILDING SIDE OF THE SUPPLY IS NOT COPPER TUBING AS REQUIRED ON THE PUBLIC MAIN SIDE OF THE PIT.

SUPPORT BRACKET SHOULD BE A MINIMUM OF 1/2" PVC PENETRATING BOTH SIDES OF THE PIT WALL AND ATTACHED SECURELY TO THE BOTTOM OF THE YOKE BAR.

**STANDARD INSTALLATION FOR
3/4" AND 1" WATER METER
SETTINGS**



BUTLER COUNTY
WATER AND SEWER

130 HIGH STREET
HAMILTON, OH 45011
TELEPHONE: 513-887-3066
FAX: 513-887-3777