


- NOTES:
- 1) HINGE, HASP, ANCHOR BRACKETS & BOLTS ARE T-304 S.S.
  - 2) THE MANHOLE BARREL IS 1/2" (MINIMUM) THICK FRP.
  - 3) NEOPRENE BOOTS ARE SECURED WITH S.S. BANDS.
  - 4) THE MATERIAL IS FRP (FIBERGLASS REINFORCED POLYESTER).

NOTE:  
RECOMMEND CONTRACTOR TO FILL  
MANHOLE WITH CONCRETE OR SAND  
COVERED WITH CONCRETE TO THE  
TOP OF THE FLUME.



PLASTI-FAB  
TUALATIN, OREGON

**6" PARSHALL FLUME  
PACKAGED METERING MANHOLE  
5' - 0" DIA.**



BUTLER COUNTY  
WATER AND SEWER  
130 HIGH STREET  
HAMILTON, OH 45011  
TELEPHONE: 513-887-3066  
FAX: 513-887-3777