

## Butler County, Ohio Water & Sewer Department Wastewater Discharge Limitations

### Local Limits for Dischargers to the LeSourdsville Regional WRF

<b>LeSourdsville Regional Water Reclamation Facility</b>	
<b>Pollutant</b>	<b>Local Limit (mg/l)</b>
Barium	12.65
Cadmium	1.14
Chromium, Total	3.71
Copper	4.58
Lead	5.15
Mercury	0.00055
Nickel	3.26
Strontium	65.37
Zinc	11.01
Chlorine	100
Oil & Grease, Total	200
pH	5.5 SU – 10.0 SU (acceptable)

### Local Limits for Dischargers to the Upper Mill Creek Regional WRF

<b>Upper Mill Creek Regional Water Reclamation Facility</b>	
<b>Pollutant</b>	<b>Local Limit (mg/l)</b>
Cadmium	0.24
Chromium, Total	4.76
Chromium, Hexavalent	0.63
Copper	2.08
Lead	0.74
Mercury	0.0009
Nickel	3.57
Selenium	0.14
Silver	1.51
Zinc	1.44
Chlorine	100
Oil & Grease, Total	200
pH	5.5 SU – 10.0 SU (acceptable)

Limits approved by the Butler County, Ohio Board of Commissioners, November 6, 2008 by Resolution #08-11-2000; Limits approved by the Ohio EPA, February 10, 2009